



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE SERVICE
TRIPURA: :AGARTALA

Phone: 0381-232-6451. Fax: 0381-2324826. Email: tripurafirenoc@gmail.com
Website: www.fireservice.tripura.gov.in

FORM -V

Form of No Objection Certificate / Fire Safety Certificate

With reference to your compliance report under no. _____ dated _____ I hereby certify that the building as per description below at the premises/ building _____ has been inspected by the officer concerned of this department on _____ in respect of implementation of inbuilt Fire Fighting, Fire Prevention and means of escape measures and found that said buildings have complied with the Fire Prevention and fire safety requirements in accordance with NBC Part-IV, Indian Standard Specification and relevant Building Rules . The premises/building is declared fit for occupancy class _____ with effect from _____ for a period of _____ years in accordance with renewed and subject to compliance of the conditions mentioned overleaf.

Issued on _____ at Agartala by.

Director of Fire Services,
Tripura: Agartala.

Memo No. F. _____ /TFS/20 / Dated, Agartala, the _____ 20

Copy to:-

1. The Commissioner/ Executive Officer..... for information and necessary action.
2. The Divisional Fire Officer, for information and necessary action.
3. The..... for information and necessary action.

Director of Fire Service,
Tripura: Agartala

Atul Steel

UJ
(UTTAM KR. BHAUMIK, IPS)
Joint Director Fire Service,
Tripura, Agartala.

PTO

Conditions for the Validity of Fire Safety Certificate/NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

***** *WE SERVE TO SAVE* *****

